

1. Roads / Sidewalks

- a) Grade roads and some back alleys
- b) Repair gas leak at Dental Office
 - i. Renters could smell gas in the building and called Alta Gas in to investigate. AltaGas got strong readings on the west side of the building where the meter is located. Gas leak was detected on a 1 1/8th steel pipe going from the metre under the sidewalk and into the basement.
- c) Met with Troy from the Regional Landfill about damage to garbage bin lids. Inspection of all garbage bins about halfway complete, hoping to meet again on April 25, to complete inspections.
- d) Met with EMCON in regards to street sweeping along highways & boulevards
- e) Dust control complaint from residents coming in- Should we have a program put in place?
- f) Tree trimming requests 50A Ave boulevard
- g) Some street sweeping compete

2. Water/Wastewater

- a) Vac PRV vault
- b) Repair main valve top box on 48 Ave
- c) Work started at distribution pumphouse to bring UFD control to PLC
- d) Met with Randy regarding lift station pump swap
- e) Shut water off and remove meter at local business as per request
- f) Main break on 54 Ave – bolts rusted off high max clamp at transition from concrete asbestos line to blue max poly line, repaired with stainless steel clamp and water restored
- g) Power failure – both distribution and sanitary systems working on back up power systems approx. 3 hours
- h) 50 Ave main break – circular break repaired under positive pressure. Complaint received regarding notice given; new protocol adopted & door hanger notices ordered
- i) Seasonal Bacti sample taken at Golf Course
- j) CC Valve repaired and line thawed at Sunshine Reflexology
- k) Met with Randy regarding UFD progress and AB Environment inspection response
- l) 2 residences taken off temporary service
- m) Began rip rap repairs on quarterly and annual lagoons

3. Other

- a) Respond to service requests
- b) Order signs for inventory and replace damaged and faded
- c) Gateway maintenance program to begin in May – pump should be 2 weeks away and ready for install beginning of June

- d) Equipment maintenance
- e) Geleta park opening April 23, ball program begins – no water til May long