



1. Roads / Sidewalks

- a) Grade all roads and back alleys
- b) Remove ice from gutters and catch basins
- c) Apply beet juice to intersections as required (400 Litres)
- d) Sand and salt along curb and gutter on 49 st in front of the Post office (3 yrds)
- e) Load and haul snow from all roads
- f) Sweep all Town owned sidewalks
- g) Grade hall parking lot

2. Water/Wastewater

- a) Exterior lights at reservoir pump house repaired by Zayaks Electric.
- b) Main break on 47th street – ABENV notified and 1st call made
- c) Residents given written and verbal disruption notices
- d) Water restored twice daily until repair completed
- e) Isolated, located, excavated, repaired, flushed, and tested as per Code of Practice
- f) 7-day letter to ABENV completed and sent
- g) Lakeland Fire and Safety performed SCBA (self-contained breathing apparatus) fit tests on ALL public works employees as per OHS.
- h) Supplied 2 new SCBA units for Sanitary Lift Station to replace outdated units.
- i) EMERGENCY RESCUE DRILL performed at Lift station wet cell with ALL public works staff as per OHS.
- j) OHS compliance report completed and submitted
- k) Month end meter reads and reporting done
- l) Annual Federal waste water report completed and submitted
- m) Gel standard tests
- n) Replaced 2 frozen water meters as per requests
- o) Vac PRV vault
- p) Back up generator test at lift station
- q) Pump house housekeeping
- r) Continue monitoring well house furnace- southside water pressure
- s) Reservoir pump house orientation for new Vegreville Water operator to replace Marvin.

3. Other

- a) Grade cemetery
- b) Repair sign posts 50 ave and 51 st
- c) Steam ice from 49st storm line out fall (Urlacher)
- d) Repair hydraulic hose on John Deere grader
- e) Service all equipment
- f) Complete all service requests

