



1. Roads / Sidewalks

- a) Complete milling, paving and sweeping and paving at 50 Ave between 49 and 50 St
- b) Haul remainder of crushed asphalt from lagoon storage yard to industrial road for mixing with SB90 oil
- c) Mix in 20 cubes of SB90 oil with crushed asphalt, gravel grade and rotovate
- d) Grade reclaimed asphalt and cold mix into windrow and haul to lagoon storage yard from 50 A ave and 45 st
- e) County supplied reclaimer for 50 Ave & 45 St
- f) Start grading and packing 50 A Ave
- g) Lower manholes and water valve boxes on 50 A ave
- h) Grade industrial road, UFA frontage, Fas Gas, 52 Ave, 45 Ave
- i) Repair intersection at 55 Ave 46 St
- j) Fill major pot holes

2. Water/Wastewater

- a) The Town experienced one short power failure since last report, system ran on generators, no issues
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) Lagoon levels monitored
- d) Continue mapping for lead management plan
- e) Attended Health and Representative webinar – received certification
- f) Manhole checks
- g) Gel standard tests
- h) Augured and recorded line of commercial sanitary service as per request
- i) Cleaned sanitary lift station wet cell
- j) Back up generator test at lift station
- k) Pump house, housekeeping
- l) Continue monitoring south side water pressure
- m) Investigate high flow rate at sanitary lift station on June 19th – determined to be infiltration – monitoring high infiltration locations on 46 ave and 55 ave
- n) Several water meter installations as per requests
- o) Weed whipped and visually inspected fire hydrants
- p) Request to turn off residential at cc valve – unable to turn old valve, had to hydrovac valve in order to turn
- q) Covid 19 protocol for Bacti samples has changed – we can now take Bacti samples to the Health unit at the hospital

Green dye spill at truck fill location – customer overfilled tank resulting into some green dye spilling onto the gravel and staining it. Customer reported to Public Works and Operator notified – Public Works informed the spill was not a reportable contravention.





3. Other

- a) Remove old gutter and sidewalk and pour new ones at 5004-5006 45 st
- b) Roof replacement completed, new furnace and hot water tank installed at Library
- c) New Massey tractor delivered by Ireland Equipment
- d) Inspection and Clean up done at the swimming pool
- e) County sprayed weeds at 5402 46 Ave
- f) Mow and weed whip all Town grass
- g) Service and repair all mowing equipment
- h) Complete all service requests

