



1. Roads / Sidewalks

- a) Clean and maintain Town sidewalks
- b) Grade along sidewalks for drainage

2. Water/Wastewater

- a) The town experienced no power failures since last report All systems good
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) Lift station call out- high room temp- on call responded turned down heat now that warmer weather
- d) Responded to 1 frozen service call and thawed 1 residential sanitary and 1 commercial sanitary
- e) Replaced frozen water meter at residence
- f) Gel standard tests and pumphouse CL2 analyzer recalibration
- g) Monitoring distribution flow rates
- h) Cleaned truck fill pad
- i) EPCOR water shut in Feb 22nd to 25th water restriction lifted
- j) Truck fill line raised to prevent pooling and allow drainage – eliminate freezing issue (rubber mounts had deteriorated and line settled)
- k) Contacted Green Hills in regards to quote on insulating and cladding Sanitary Lift station in order to maintain consistent room temp regardless of weather conditions
- l) Checked storm drain outfalls and catch basins

3. Other

- a) Thaw frozen sewer line at 5024-51 St & 5008-51 St
- b) Replace frozen meter at trailer court 4613-56 St
- c) Replace leaking hoses on single axle dump truck
- d) Assist with Hillside lodge job – sewer replacement
- e) Assist Grayson Excavating with line locates, camera and material for backfill
- f) Haul out asphalt, sidewalk and tree stumps
- g) Respond to all service requests

