

Roads / Sidewalks

- a) Grade all roads and back alleys
- b) Finish removing snow and ice from culverts, catch basins and ditches
- c) Apply sand & salt on intersections as required
- d) Haul snow and windrows from the roads and back alleys

Water/Wastewater

- a) The town experienced no power disruption since last report - all systems good
- b) Gel standard tests and cl2 analyzer calibrations done
- c) Manual meter reads as per admin
- d) Continue to monitor pressure and flow rates
- e) Sunday March 5 - call out for frozen sanitary line on 57Street - thawed 2 lines and
- f) restored flows
- g) ACE control valve replaced in reservoir pumphouse - new valve failed to shutdown on fill cycle and Ace fill needed to be closed manually. Techs returned and adjusted programming and reset solenoids. Valve is working correctly now
- h) Water service disconnect as per request
- i) Manhole checks around town

Other

- a) Grade snow and ice from the Hall parking lot for drainage
- b) Service all equipment
- c) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

