

Roads / Sidewalks

- a) Grade, load and haul snow off all Town roads
- b) Apply beet juice and sand to all intersections and roads as required (5000 L of beet juice & 12 yrds of sand and salt)
- c) Sweep and apply ice melt to all Town sidewalks
- d) Remove snow from back alleys as required

Water/Wastewater

- a) The Town experienced 3 power disruptions since last report --- all systems good
- b) Residential meter checked - discovered leaking toilet on premises
- c) 57 Ave manhole checked as per winter routine
- d) PRV vault vac'd
- e) 50Hp pumps exercised at Reservoir pumphouse
- f) Well house furnace checked
- g) AB ENV annual reporting finished, signed off and submitted for 2022
- h) Federal water reporting finished, signed off and submitted
- i) Met with ACE rep and engineers regarding potential short-term disruption of Bulk water sales at Reservoir truck fill during tie in to new water line to Duvernay
- j) Expose several fire hydrants from drifting snow
- k) Manhole checks at all potential problem locations
- l) Manually fill barrel fill customers in pumphouse
- m) Update contacts for Pumphouse and Lift station
- n) Update Pumphouse Operations program and S.O.G
- o) Continue to monitor flow rates
- p) Calibrate Reservoir cl2 analyzer
- q) Gel standard test hand held CL2 analyzers
- r) Month end reporting and meter reads
- s) Large water break on Jan 19th @ 12:02 pm - alerted to break by pumphouse pressure and flow alarms. Break located and isolated by 12:55pm - approximate water loss 54M3
- t) Break excavated, located and repaired by replacing cast 6-inch Tee with Blue poly 90 degree - additional leaks identified and repaired with 6-inch stainless steel repair clamp and 6 inch stainless with 1 inch service repair clamp.
- u) Cl2 swabbing, flushing, testing and Bacti samples done as per code of practice and samples delivered to Provincial Lab at UofA as per requirement

Other

- a) Replace and repair 17 garbage bin lids
- b) Service and repair all snow removal equipment
- c) Drive dump truck to Edmonton for repair, new fuel pump and intake control valve
- d) Complete all service request

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

