

Roads / Sidewalks

- a) Repair and Fill with cold mix waterline excavation sites on 47 Ave and 46 St
- b) Fill waterline repair excavation on 52 Ave, 48 Ave with SB90
- c) Fill potholes on 47 St, 47 Ave, 49 St, 44 St, 45 St and 49 Ave
- d) Sweep 47 Ave, 46 St, 50 A Ave, 50 Ave, 48 Ave, 49 St
- e) County rotovated 54 St, 54 Ave and 53 Ave Grade, load and haul reclaimed asphalt to the lagoon and stock pile it, grade and pack base to grade
- f) County rotovated 53 A Ave, 47 A St, load and haul reclaimed asphalt to the lagoon and stock pile it, grade and pack to grade
- g) Grade 46 Ave between 54 St and 56 St, 52 St between 50 Ave and 52 Ave, 52 Ave from 51 St to 53 St wet down roads and spread 2 tonnes of Mag crystals for dust abatement

Water/Wastewater

- a) The Town experienced 5 power disruptions since last report (2 lasted over 4 hours) --- all systems good
- b) Calibrate and recertified pumphouse cl2 analyzer
- c) Assist bulk water customers as per request
- d) Summer lagoon treatment program continuing
- e) Pw foreman training to fill in with water/ wastewater role
- f) 2 Bacti samples failed to be processed so samples taken to Prov Lab in Edmonton
- g) Visual inspection of lagoons
- h) Sanitary Lift Station wet cell cleaned by public works
- i) Water valves and manholes located by public works for road reclamation
- j) Continue to monitor flow rates
- k) Gas monitors for lift station recalibrated
- l) Ph and ammonia samples taken at lagoon (waiting for test results to begin early release)
- m) Note: Planning an early lagoon release so release valve can be excavated and repaired/replaced as required

Other

- a) Mow and weed whip all Town properties
- b) Service and repair all mowing equipment
- c) Water flowers
- d) Complete all service requests

