



Roads / Sidewalks

- a) County reclaimer completed rotovating 47 Ave from 46-48 St
- b) Grade and haul reclaimed asphalt from 47 Ave
- c) Complete backfilling and road surface of the new curb and gutter on 52 Ave between 49 St and 50 St
- d) Excavate top soil from north side of 45 Ave and replace with clay
- e) Haul, grade and pack gravel on 45 Ave to proper grade for paving
- f) Grade 55 Ave

Water/Wastewater

- a) The town experienced two power disruptions since last report - all systems good
- b) Large Bird hit the power line west of lift station again causing the line to trip the breaker at lift station. PW on call responded to the alarm and notified Atco who reset the power. Second was a short power failure in town
- c) Final lagoon mowing completed for the season
- d) Preparations for annual release in October started
- e) Continue to monitor 46th Ave sanitary flow
- f) Several non payment disconnects were completed
- g) Two reconnects done upon receipt of payment
- h) Sanitary manhole checks done on 50 street,
- i) Monitoring south side water pressure
- j) Monitoring distribution flow rates
- k) Attended online WCW waste water sessions
- l) Use of mobile emergency lift stations
- m) Hydrogen peroxide for odour control
- n) Passive nutrient reduction in lagoon systems
- o) Locate main valves and manhole for reclamation project on 47th Ave
- p) Lift station generator test
- q) 4-inch water line added from 45th Ave down 54th Street on west side of Centennial Arena for future water demands.
- r) Installed, pressure tested, flushed and sampled as per code of practice

Other

- a) Complete hauling and leveling of screened dirt along new curb in Geleta Park
- b) Haul excess clay to lagoon from water line install on 45 Ave
- c) County mixed SB90 with reclaimer
- d) Install new covers on storm line in Mennonite School yard
- e) Install top and catch basin on vault at Geleta Park storm line

