



Roads / Sidewalks

- a) Grade back alleys where required
- b) Haul and replace reclaimed asphalt on 54 Ave
- c) Grade industrial road
- d) Fill pot holes

Water/Wastewater

- a) The Town experienced 1 power disruption since last report --- jockey pump failed to restart until alarm reset but pump 4 engaged - jockey reset - all systems good
- b) Calibrate pumphouse cl2 analyzer
- c) Gel Standard tests completed
- d) Spring lagoon treatment program started - thermal turnover odours minimal
- e) 50Hp pump #4 exercised at Reservoir pumphouse
- f) Steamed residential cc valve to close for work inside of house
- g) Visual inspection of lagoons
- h) 2 - 7day letters for main breaks sent to AB ENV as per code of practice
- i) Limited access to bulk water fills at reservoir for a couple of days while tie in to ACE water line completed in north pumphouse approach
- j) Communications failure at Reservoir - resolved by ACE - fill valve failing to close completely
- k) Opened RV dump - flushed and Bacti tested
- l) Seasonal Bacti Samples taken at: G.O's, Golf course, Geleta Park gate washrooms
- m) Manually fill bulk water customers affected by communications problem with truckfill uploads
- n) Month end reporting
- o) Continue to monitor flow rates
- p) Pumphouse orientation with new Vegreville/ Ace operator

Other

- a) Sweep gravel off the grass along 55 Ave and hall parking lot
- b) Clean up gravel from snow dumping sites
- c) Complete gopher extermination at Town sites
- d) Deliver 18 flower pots to Fjeldstroms
- e) Service and replace brooms on the street sweeper
- f) Service all mowing equipment
- g) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

