

Roads / Sidewalks

- a) Final grading and packing on 45 Ave done for paving
- b) Dig out old asphalt and top soil on 52, 53, & 54 St for paving tie in and haul away
- c) Backfill with SB90 along new sidewalks on 52 Ave between 46 and 45 Ave and pack
- d) Back fill with topsoil on 52 Ave sidewalk at resident property
- e) Fill the sinkhole on 46 St and 49 Ave with gravel and top it off with cold mix

Water/Wastewater

- a) The town experienced one power disruption since last report - all systems good
- b) Locate, test and repair cc valves at sidewalk replacement locations
- c) Repair truck fill hose
- d) Continue to monitor pressure and flow rates
- e) Service ½ inch prv valve in reservoir pumphouse to restore proper flow to sampling location
- f) Sanitary Lift station generator annual service performed by PEAK
- g) Force main flush at lift station and check outfall at lagoons
- h) Manhole checks around town
- i) Lagoon survey completed by Algae control Canada
- j) Met with Algae control techs at lagoons pre job safety meeting and orientation
- k) Once survey is logged and analyzed they will send us the report
- l) THM samples taken (bi annual)
- m) Operator trainee attended AWWOA fire hydrant maintenance course

Other

- a) Remove old sidewalk on 52 St and 49 St
- b) Remove and haul away old asphalt and top soil from the west side of the hall for new cement HVAC pad (June 8th)
- c) Mow all Town grass
- d) All Town properties sprayed for weeds
- e) CVIP done on the Vac Truck
- f) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

