



1. Roads / Sidewalks

- a) Complete sidewalk, curb & gutter on 49 Ave & 44 St
- b) Complete road surface and backfill on sidewalk and gutter on 49 Ave and 44 St
- c) Start removal of sidewalk at arena

2. Water/Wastewater

- a) The town experienced 1 short power failure since last report – System ran on generators – 1 VFD failed in Reservoir pumphouse. Nacon will be repairing
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) Lagoon levels monitored
- d) Continue mapping for lead management plan
- e) Vac'd PRV and flushed sanitary mains
- f) Gel standard tests and pumphouse CL2 analyzer recalibration
- g) Augured residential sanitary service as per request - unsuccessful
- h) 2 residential sanitary lines were cleaned with vac truck and camera inspected
- i) 49 Ave locates done
- j) Pump house housekeeping
- k) Continue monitoring south side water pressure
- l) Investigate high flow rates on distribution system – still appear to be higher than normal
- m) water meter installation as per request
- n) Locate golf course cc valve as per request
- o) Numerous requests to turn off residential service at cc valves for non payment
- p) Began facility inspections for Health and Safety
- q) Water restored and sewer line inspected with camera as per request by bank
- r) Investigate wet spot by Co-op – attributed to ground water coming from pad- continuing to monitor
- s) Checked 46 street Storm drain for unusual flow – continue to monitor
- t) Hydro jetted (Urlacher) and vac'd Sanitary mains:
 - a. 50 Ave east of 48 St
 - b. 51 Ave north to 52 Ave (47 St)
 - c. 51 Ave north at 47 St
 - d. 46 Ave east to trailer park
 - e. 46 Ave north at trailer park
 - f. 53 St south to rec center
 - g. 54 St south to arena
 - h. Note: south side lines are very flat with low flow
- u) Geleta park gate washrooms winterized

3. Other

- a) Service and repair all road equipment
- b) Remove asphalt overlay on sidewalk on east side of 45 St
- c) Repair vac truck oil leak on front axle
- d) Water flowers
- e) Complete all service requests

