



1. Roads / Sidewalks

- a) Complete grading and hauling snow off all town roads
- b) Grade all back alleys
- c) Apply beet juice to problem icy intersections and roads

2. Water/Wastewater

- a) The town experienced no power failures since last report
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) Sent H2S gas monitors for recalibration
- d) Investigated (SEGO) drive line noise at Lift station, determined to be coming from steady bearing – running pumps in lead/lag setting to prevent additional wear until bearing can be replaced
- e) Continue south side pressure checks
- f) Manhole checks
- g) Gel standard tests and pumphouse CL2 analyzer recalibration
- h) Monitoring distribution flow rates
- i) PRV
- j) Meter reads and month end reporting
- k) AB ENV wastewater annual reporting (continued)
- l) Reservoir housekeeping
- m) Barrel fill at truck fill is closed for winter due to freezing (every winter)

3. Other

- a) Sweep snow off all the Town sidewalks and apply salt where required
- b) Weld stop sign back onto base at the corner of 50 St and 47 Ave
- c) Complete all service requests

