

Roads / Sidewalks

- a) Repair the intersection at 46 St and 47 Ave
- b) Repair excavation across 47 Ave done for storm line installation
- c) Construct berm along south side of CO-OP property
- d) Locate and adjust main water valve top boxes and manhole covers on 53 Ave, 52 Ave and 47 St.
- e) Sweep gravel off the intersection at 46 St and 47 Ave

Water/Wastewater

- a) The town experienced 1 power disruption since last report- short power failure affecting the sanitary lift station - all systems good
- b) Gel standard tests and cl2 analyzer calibrations done
- c) Restore residential water service as per request
- d) Continue to monitor pressure and flow rates
- e) Preheat furnace gas valve replaced at Sanitary Lift station
- f) Month end water meter reads
- g) 3 manual meter reads
- h) Manhole check on 57Street
- i) Generator test at lift station
- j) Oil pressure sensor on back up engine replaced by PEAK and Engine driven pump tested
- k) Condition B water restriction (no unnecessary water use) put in place and lifted for work being done on ACE distribution line
- l) Begin working on AB ENV annual reporting
- m) New meter install as per request
- n) Annual lagoon release started Oct 17th
- o) Lagoon release valve seized and difficult to open- will need to clean at end of release and may need to excavate and repair
- p) Remainder of required samples taken and sent for analysis as per release requirements
- q) Begin transition into new wastewater treatment protocols at lift station and lagoons
- r) Begin changing water meter registers and transmitters in municipal, commercial and mobile homes
- s) Begin fire hydrant winterizing

Other

- a) Haul, level and seed grass at 47 Ave after storm line installation
- b) Haul, level and seed grass at the north east side of CO-OP
- c) Unload and place the new HVAC unit on the cement pad on the west side of the hall
- d) Check and repair lifting brackets, lids and lid rods on garbage bins
- e) Service and repair sanding unit (batteries, slip clutch, weld brackets, sander box chain)
- f) Winterize and store all mowing equipment
- g) Service and repair snow removal equipment

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

