



## 1. Roads / Sidewalks

- a) County reclaimed 51 Ave between 46 & 49 St, 46 Ave between 51 & 52 St, 52 St between 45 & 46 Ave
- b) Haul 60 truck loads of reclaimed material to industrial road for mixing with SB90 oil
- c) Windrow reclaimed material on 52 St, 46 Ave
- d) Dig and haul out top soil on 51 Ave
- e) Grade industrial road 51 St, 55 Ave
- f) Build temporary approaches on 51 Ave

## 2. Water/Wastewater

- a) The town experienced 3 power failures since last report-All systems good
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) 2 -room temperature alarms at Sanitary Lift station; 1 required removing winter cover from fresh air fan and 2nd due to generator running during power failure
- d) Seasonal Bacti samples taken at RV dump station, Geleta Park exhibit building, ball diamonds, gate wash rooms and park washrooms
- e) Spring lagoon inspection on facultative pond ... requires some minor rip rap repairs
- f) Annual chlorine pumphouse chlorine analyser service and recertification (Capitol H20)
- g) Residential sewer line replaced from property line to main on 51st ave
- h) Monitoring distribution flow rates
- i) Locate and expose cc valves, main valves and manholes for 51st ave project
- j) Excavate and replace residential cc valve
- k) All 20 lead samples taken and sent to lab as per requirements – sample result notification letters will be sent to residents when samples results are returned
- l) New water meter install at new home
- m) Commercial property sewer line auger
- n) 1st call water/sewer locates for resident as per request

## 3. Other

- a) Remove old sidewalk on 51 Ave between 46 & 48 St and haul it to lagoon sidewalk stock pile
- b) Complete all delivery requests of gravel, reject and top soil
- c) Change cutting edges on Volvo loader and grader
- d) Replace rear broom drive motor on street sweeper
- e) Straighten and weld tailgate on tandem dump truck

