



1. Roads / Sidewalks

- a) Maintain sidewalks
- b) Sand and salt roads
- c) Haul windrows to snow dump

2. Water/Wastewater

- a) The town experienced no power failures since last report All systems good
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) Lift station call out- low room temp- on call responded below minus 40 -frost on exterior wall affected alarm thermostat – placed a cardboard barrier between thermostat and wall and plugged-in heater beneath
- d) Cross shift responded to 3 frozen service calls and thawed and 1 residential sanitary
- e) Low CL2 alarm from Ace analyzer in pumphouse – notified ACE operator due to part failure, removed old line from ACE analyzer to be repaired- numerous low cl2 alarms late night – called Nacon to disable alarm until repair made following morning
- f) Gel standard tests and pumphouse CL2 analyzer recalibration
- g) Monitoring distribution flow rates
- h) Cleaned and Salted truckfill pad
- i) Notified of EPCOR water shut off period Feb 22nd to 25th water restriction in effect – minimize consumption until then in case EPCOR forced to shut down early.
- j) Truck fill frozen – notified fire dept and posted – thawed with washgun from outside (county truck fill frozen as well)
- k) Water main break on 52 Ave & 50 St (by RCMP Station) – repaired by Terry’s shift (Murray and Bob assist) Circular break in 4-inch line - repaired flushed and tested as AB ENV
- l) Scheduled PRV service in reservoir pumphouse (March 3)
- m) Water main break on 47 Ave (by Martens Auto Shop) – Repair by Murray’s shift (Terry and Aaron assist) Repaired flushed and tested as per AB ENV

3. Other

- a) Assisted cross shift with main break repairs
- b) Shut in 47 Ave water break and repair
- c) Forman pick up truck taken to dealership for transmission repair – repaired under warranty

