

## Roads / Sidewalks

- a) Grade industrial road
- b) Grade back alleys
- c) Remove old asphalt from the intersection at 49 St and 50 Ave. Grade and pack cold mix
- d) Fill potholes on 46 Ave, 55 Ave & 46 St
- e) Grade and rotovate gravel & SB90 oil in the industrial park
- f) Start culvert install on 47 Ave
- g) County will start reclaiming 52 & 53 Ave between September 12-14<sup>th</sup>

## Water/Wastewater

- a) The town experienced 2 power disruptions since last report - 1st power failure lasted approximately 4hrs- back up engine shutdown and had to be manually reset due to oil pressure sensor failure. Unit checked by Peak, oil pressure gage added and replacement sensor ordered.
- b) 2nd power failure approx. 10 minutes - all systems good
- c) Gel standard tests and cl2 analyzer calibrations done
- d) Restore residential water service as per request
- e) Continue to monitor pressure and flow rates
- f) Non payment water disconnects as per office
- g) Seasonal Bacti tests taken for school openings
- h) 1 residential sewer auger job as per requests
- i) Manhole checks around town
- j) Engine driven pump test at water reservoir
- k) Replace 2 residential cc valve top boxes and rods
- l) H2S gas monitors recalibrated by Lakeland Fire and Safety
- m) Vac PRV vault behind public works
- n) Flush and vac several sanitary mains around town with Urlacher
- o) Replace lockset and get keys cut for water tower
- p) Summer student and motorcycle tourism employee finished for the season
- q) 1st calls and locates for reclaiming and culvert projects done
- r) Weed whip lagoon discharge swale in prep for annual release
- s) Manhole directly north of sanitary lift station in old rail bed in need of repair
- t) Month end meter reads
- u) Reviewed AC Control Canada lagoon treatment proposal
- v) Lambourne lagoon cleanout estimate approximately \$80,000 (Quote to Randy Cyba)

## Other

- a) Service and repair dump trucks, mini hoe, track hoe and mowing equipment
- b) Replace lids and weld brackets on 5 garbage bins
- c) Hydrovac gas lines on 47 Ave for culvert install
- d) Haul stolen chain link fence and poles back to PW yard
- e) Complete all service requests

**Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.**

