



1. Roads / Sidewalks

- a) Complete mixing of SB90 oil and gravel
- b) Haul grade and pack SB90 on 51 Ave
- c) Haul reclaimed SB90 from 46 Ave from 51 St to 52 St between 45-46 Ave
- d) Haul, grade and pack new gravel on 52 St for base material
- e) Fill and pack gravel along new sidewalk at the Hall
- f) Haul, grade and pack SB90 along new sidewalk on 47 A St, 52 Ave, 48 St and 52 Ave
- g) Sweep up gravel, screenings and dirt on 47A St, 52 Ave, 49 St, 47 St

2. Water/Wastewater

- a) The town experienced no power disruptions since last report
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) 3 High room temperature alarms at Lift station – checked by Bob and on call and alarms reset. Due to high temperatures on outside walls from sun
- d) Condition B water restriction implemented June 28th due to high demand
- e) June 29th instructed by ACE operator to close Reservoir truck fill
- f) July 5th opened truck fill for human consumption only as per instructions
- g) July 5th – Condition B lifted
- h) July 6th Human consumption only notice removed from truck fill
- i) Filled water tank for Grow Arena Project spraying (8.5 m3)
- j) Sanitary manhole checks done north of Hwy 45, 53rd street and 54th street north of 50 Ave
- k) Residential sewer line augured on 46th street – blockage at approx. 80 feet
- l) Monitoring distribution flow rates
- m) Water service restored to residential property and frozen water meter replaced as per request
- n) Water reported to be coming up on commercial property – tested and determined to be chlorinated water, CC valve closed and flow stopped, property owner responsible for repairs. Water not restored until completed
- o) Bacti sample taken at Centennial Hall before re- opening
- p) CC valves checked on 47 A Ave – 3 replaced
- q) CC valves checked on 49 Street – 2 replaced – 1 within yard to be replaced at a later date
- r) CC valves checked 50 Street – 1 replaced
- s) CC valves checked 52 Street – 1 replaced
 - a. Note: Above CC valves were checked for sidewalk replacement work

SUMMER TEMP WORKERS REPORT

- a) The towns summer employees have started and are catching up on weed whipping, grass cutting
- b) Flower and Tree watering continues on Mon – Wed – Friday schedule
- c) The CMTA (Wayside) worker continues to assist with watering, potholes and grass cutting

3. Other

- a) Remove and haul old sidewalks on 46 Ave, 52 St, 49 St, 50 St, 47A St and 52 Ave
- b) Haul away top soil and clay from all sidewalk projects
- c) Replace starter on BL580 Volvo Backhoe
- d) Purchase new Stil weed whipper
- e) Repair and service grader, John Deere tractor and rotovator
- f) Complete all service requests

