

## 1. Roads / Sidewalks

- a) Spread gravel on dust abatement routes
- b) Repair and service packers for MG-30 application
- c) Lower manhole on 54st at 53 Ave
- d) Control gopher population with County gophinator
- e) Maintain parks; rotovate sand, cut grass & water flowers (including Senior centre, Pioneer Park & Cenotaph)
- f) Install culverts at 57 Ave & 47 St and build approach
- g) Sweep some streets after the rain

## 2. Water/Wastewater

- a) Fish eye submersible reservoir inspection – no sign of cracks or anything requiring repair, very little sediment cleaning not required at this time
- b) Black dirt and grass seeded at reservoir to repair settled spots on reservoir berm
- c) Pumphouse natural gas engine annual service completed
- d) Alarm tests and annual CL2 analyzer service completed
- e) Engine driven pump tested at reservoir
- f) Investigate leak at Burger Palace – leak is after CC valve
- g) Meter removed from mobile home on 51 st CC valve leaking – first calls made to do valve repair
- h) BACTI samples not processed due to not being received in 24 hr. window, following up to see why samples are not being processed at lab within 24 hours

## 3. Other

- a) Respond to service requests and 1<sup>st</sup> call utility locates
- b) Met with insurance representative for recorded meeting in regards to residence insurance claim
- c) Yearly service on reservoir engine
- d) Canada day preparation?