

Roads / Sidewalks

- a) Grade, load and haul snow off all Town roads
- b) Finish removing snow and ice from culverts, catch basins and ditches
- c) Pile up snow at both snow dumping sites

Water/Wastewater

- a) The town experienced no power disruption since last report - all systems good
- b) Gel standard tests and cl2 analyzer calibrations done
- c) Manual meter reads as per admin
- d) Continue to monitor pressure and flow rates
- e) Sunday March 5 - call out for frozen sanitary line on 57Street - thawed 2 lines and
- f) restored flows
- g) ACE control valve replaced in reservoir pumphouse - new valve failed to shutdown on fill cycle and Ace fill needed to be closed manually. Techs returned and adjusted programming and reset solenoids. Valve is working correctly now
- h) Water service disconnect as per request
- i) Manhole checks around town

Other

- a) Sweep and salt Town sidewalks as required
- b) Service and replace broom sections on skid steer sweeper
- c) Service and repair all snow moving equipment and sanding unit
- d) Supply gravel and screenings for back filling power supply at Hall and Rec Centre
- e) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

