



1. Roads / Sidewalks

- a) Complete reclaiming, grading, hauling packing, apply tack oil material to 49 St, 52 Ave, 50 St, 48 Ave, 46 Ave and 52 St
- b) Back fill all new sidewalks and gutters with screened dirt.
- c) Start work on 45 Ave. Removing concrete, top soil and sign posts
- d) Replace broken main valve top boxes on 52 Ave and 50 St
- e) Fill major potholes with cold mix

2. Other

- a) Mow all town properties
- b) Repair grader circle turn gear box
- c) Service all road equipment
- d) Complete all service requests

Water/Wastewater

- a) The town experienced one power disruption since last report - all systems good
- b) Annual Rip Rap repairs completed at waste water lagoons
- c) Continue to monitor 46 Ave sanitary flow
- d) Hand held Cl2 analyzers annual recertification completed
- e) H2S gas monitors from Sanitary lift station re-calibrated
- f) Sanitary manhole checks done east of Hwy 36
- g) Monitoring south side water pressure
- h) Monitoring distribution flow rates
- i) Water service restored to residential property as per request
- j) Lagoons inspected and mowed
- k) Lift station generator test
- l) July 29th AirNac valve failed on jockey pump in Reservoir pumphouse
- m) Valve isolated removed and replaced with same from Lag 2 pump
- n) Lag 2 pump isolated and locked out until replacement valve arrives (approx. 16 weeks)
- o) Jockey pump restored to full service

SUMMER TEMP WORKERS REPORT

- a) The summer employees have continued weed whipping, grass cutting
- b) Flower and Tree watering continues on Mon -Wed -Friday schedule
- c) Assisted with painting of arena -inside and out
- d) Rototilled playgrounds
- e) Assisted with backfilling and clean up from sidewalk projects
- f) Begin crosswalk painting

