



Roads / Sidewalks

- a) Complete hauling, grading and packing SB90 on 47 Ave between 46-48 St
- b) Adjust height on manhole covers and water valves
- c) Pothole filling done on 53 Ave, 46 & 47 St
- d) Complete removal of SB90, packing and grading of cold mix at intersection of 46 Ave & 56 St (trailer court)

Water/Wastewater

- a) The town experienced no power disruptions since last report - all systems good
- b) PH and Ammonia tests taken at lagoon in preparation for annual release
- c) Release valve tested at lagoon
- d) Several non-payment disconnects were completed
- e) Looking into dewatering and desludging of anaerobic ponds - possible 2022
- f) Sanitary manhole checks southside,
- g) Monitoring south side water pressure and cl2 levels
- h) Monitoring distribution flow rates
- i) Attended online WCW sessions
 - a. -Water security
 - b. -waste water facility risk assessment
 - c. -cast iron main assessment
- j) Barrel fill at truck fill "out of service" due to mechanical failure (replacement solenoid on order)
- k) Lift station generator test
- l) Annual Fire Hydrant winterizing completed
- m) Month end meter reads
- n) Vac'd and flushed sanitary manhole at Eventide homes as per request
- o) 4pm Oct 6 – Notified by rental property landlord of theft of utility at southside rental property (water service disconnected due to lack of payment on Sept 13th) Bob and Ava met landlord and RCMP at property and discovered tampering with the curb shut off valve. RCMP witnessed shut off and informed resident that any further tampering with water service would lead to charges

Other

- a) Take down, empty and store all flower pots
- b) Install new flag poles at Geleta Park
- c) Pick up and store all tables and benches from the parks
- d) Start winterizing summer equipment
- e) Complete hauling, grading and packing gravel on east hall parking lots
- f) Build new cover and drain grate for vault and Geleta park gate
- g) Met with Nordic management to set up all HVAC and equipment maintenance
- h) Complete all service requests

