

Roads / Sidewalks

- a) Grade snow off all roads and cul de sacs
- b) Apply sand and salt to all roads and intersections as required
- c) Load and haul snow windrows off roads
- d) Grade parking lot at hall and arena

Water/Wastewater

- a) The town experienced 0 power disruption since last report -- all systems good
- b) Gel standard tests and cl2 analyzer calibrations done
- c) Shut off residential water service as per request
- d) Continue to monitor pressure and flow rates
- e) Shut off commercial water service as per request
- f) Sewer auger residential sanitary line as per request - tree roots on property
- g) Exercise pumps 1,2, & 3 at reservoir pumphouse
- h) Manhole check on 57 Street
- i) Generator test at lift station
- j) Water break on 53 Ave - located, repaired and tested
- k) Fire hydrant winterizing 3 hydrants- re winterized due to Fire Dept use
- l) Continue working on AB ENV annual reporting
- m) Lagoon release completed and valve cleaned
- n) Shut off water service to fire damaged home

Other

- a) Brandt (John Deere) replaced steering rod ends on the grader
- b) Repair hydraulic control on skidsteer sweeper
- c) Sweep all town sidewalks
- d) Service dump trucks
- e) Push up snow at dump site
- f) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

