

Roads / Sidewalks

- a. Grade 51 St and 55 Ave intersection, 52 Ave from 51 to 52 St, and west side of the arena parking lot.
- b. Remove old sidewalk and excavate for new curb and gutter on the west side of 52 Ave between 45 and 46 Ave.
- c. Curb & gutter complete on 52 St. Backfilling scheduled to start October 10.
- d. Repair entrance to Bumper to Bumper and Double A Trailers on 55 Ave.
- e. Repair water line breaks (excavations) on 48 Ave and 51 Ave.
- f. Change out damaged and vandalized garbage bins.
- g. Cleaned and repaired vandalized stop signs and roadway.
- h. General maintenance on all equipment.

Water/Wastewater

- a) Continue to monitor Cl2 levels throughout distribution system - levels very low but still within acceptable levels.
- b) Testing water multiple times a day, reporting to Vegreville Operator and still flushing system - ACE will reimburse for flushing.
- c) Annual lagoon release started on afternoon of Sept. 26.
- d) Generator at lift station and pump system at reservoir had annual service.
- e) Manhole with history of frozen outfalls excavated and insulated.

Other

- a. Complete spray foam on manhole on 57 Street.

