

1. Roads / Sidewalks

- a) Grade industrial road, 47 Ave, 52 St north of 50 Ave
- b) Remove ice and snow from major intersections
- c) Sand all roads; 5 loads at 3 yards per load

2. Water/Wastewater

- a) Monitor annual release progress
- b) Calibrate CL2 analyzers at reservoir
- c) Sewer auger as per resident request
- d) Badger meter reading training
- e) RV antifreeze lagoon valve
- f) Make SOG for meter reads
- g) Drip list notifications sent out
- h) Flush 50 St sanitary main from 59 Ave south
- i) Install new meter at 5008 51 St
- j) Remove meter and close CC valve at 5014 51 St
- k) Sewer auger vac truck and camera residence as per request
 - a. Found damage to sewer service within property
- l) Met with Randy and gave an onsite orientation for lift station, lagoon and pumphouse (Vegreville operator replacing Dez)
- m) Emailed Canada pump requesting update on pump & motor rebuild
- n) Annual lead and THM testing is scheduled in the upcoming few weeks

3. Other

- a) Install new 50 HP electric motor on #1 compressor at the ice plant
- b) Vac out PRV
- c) Replace burnt out lights and service grader
- d) Repair sanding box and replace spinner
- e) Inspect and repair Christmas lights
- f) Inspect and repair Christmas rope lights
- g) Put up new Christmas lights and rope lights
- h) Request quote for snow bucket from Strongco and Brandt
- i) Replace tires on both F350 trucks
- j) Complete all service requests