

Public Works Foreman Report

June 9, 2020

1. Roads / Sidewalks

- a) Continue pot hole repairs
- b) Continue road sweeping
- c) Grade industrial road
- d) Gravel and grade back alley north of 50 Ave
- e) Spectre systems milled 50 Ave to prepare for paving
- f) Contact Kortech for dust abatement for certain gravel roads.

2. Water/Wastewater

- a) The town experienced 1 power failure since last report – both Distribution and sanitary systems checked – all systems working correctly, no issues
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) Lagoon Levels monitored
- d) Annual Pumphouse Cl2 monitors recalibration completed
- e) Month end meter reads and reporting done
- f) Trihalomethane tests completed for distribution system
- g) Gel standard tests complete
- h) Camera and auger residential sanitary service as per request
- i) Lead Sampling bottles ordered
- j) Back up generator test at lift station
- k) Pump house housekeeping done
- l) Continue monitoring south side water pressure
- m) Temporary water service installed at Geleta park from Rec Center
- n) Geleta Park water tested, Bacti Sample taken and water restored for season
- o) Geleta Park gate washrooms tested, Bacti sample taken and opened for season
- p) Begin working on Lead sampling plan with Randy Cyba
- q) Covid 19 protocol for Bacti samples is to take directly to Provincial Lab at University Hospital – we are taking turns with Vegreville delivering samples to Prov Lab
- r) 3 CC valves replaced on 50 Ave for sidewalk project

3. Other

- a) Remove old sidewalk from northside of 50 Ave, dig out top soil and rocks back fill and pack.
- b) Excavate water service line and replace cc valves, rods and top boxes
- c) Finish tree planting at fish pond, Geleta park and along river
- d) Install flag pole and bird house pole at Chomlak park
- e) Spray all Town properties for weeds
- f) Install hanging flower pot brackets
- g) Hang flower pots
- h) Pick up and deliver new office furniture



Public Works Foreman Report (continued) June 9, 2020

- i) Supply vac truck to county for waterline break in Willingdon
- j) Start grass mowing in parks and road allowance
- k) Sweep highway 36 for Emcom
- l) Service and repair mowing equipment
- m) Complete all service requests
- n) Lowen Construction poured new sidewalk 50 Ave
- o) Complete orientation and safety policies for summer students

