

1. Roads / Sidewalks

- a) Repair the intersection at 50 St and 47 Ave with cold mix
- b) Grade and pack crushed asphalt on 47 Ave
- c) Grade industrial roads
- d) Grade back alleys
- e) Repair 50 Ave east of 46 St
- f) Repair catch basin on 48 Ave and 47A St
- g) Grade and pack SB90 on 45 Ave
- h) Backfill and pack along all new sidewalks
- i) Sweep up loose gravel 51 Ave, 47A St, 46 St, 45 Ave, 53 St

2. Water/Wastewater

- a) Backup generator tests done at sanitary lift station
- b) Vac PRV
- c) Lagoon Inspection with Randy Cyba
- d) Sept 12th – power failure weak batteries at reservoir pump house, back up pump, replaced batteries and tested system
- e) Canada pump and power replaced both pumps, one motor and repaired one drive shaft at sanitary lift station
- f) Isolated and cleaned wet cell vault manually and with trash pumps, public works provided VAC truck for isolation and trash bin for solids, sludge and debris. Canada pump took old pumps & motor to assess wear and provide quote as per CFO and Randy Cyba
- g) Contractor removed old galvanized plumbing and replaced at Town office, old pipes removed and valves and fittings salvaged.
- h) Monitored Canada pump well on site for safety, H₂S, confined space etc.
- i) Checked unit #1 at four plex apartments for water leak as per request, checked all fittings, meters and beneath pipe insulation (video on file) no indication of any leaks
- j) Checked 46 St manholes
- k) UFD low voltage failure at lift station, repaired by Terry Zayak
- l) Contractors drilled into water service at Mennonite School - isolated repaired and tested
 - a. Check valve opened and failed to close at hospital causing some additional loss
 - b. Large pumps shut off during water loss to slow the rate of loss due to ACE water shut in
 - c. Town pressure equalized and maintained
- m) Manholes vac'd and degreaser added at all problem spots in sanitary system

- n) Gel standards, CL2 monitor calibrations done
- o) Geleta park and gate washrooms blown out and winterized
- p) Water disconnects and reconnects done as per requests
- q) Snaked and vac'd Two Hills Inn sewer line as per request
- r) Vac PRV and flush 46 Ave east

3. Other

- a) Winterize mowers, tractor, packers and street sweeper
- b) Repair hose reel on vac truck
- c) Wash and service skid steer, loader and grader
- d) Vac out all catch basins
- e) Clean out sand and gravel from storm out fall on east storm line
- f) Clean out culverts along 47 Ave
- g) Complete all new service requests