



Roads / Sidewalks

- a) Grade snow off all Town roads
- b) Grade all back alleys
- c) Load and haul all snow windrows
- d) Load and haul snow from back alleys
- e) Apply beet juice on intersections and roads where required

Water/Wastewater

- a) Town experienced NO power disruptions since last report. All Systems GOOD.
- b) Natural Gas Regulator replaced again by APEX at the Water Reservoir Pumphouse due to venting issues with the 1st replacement regulator.
- c) Engine driven Stand-By pump tested after gas disruption.
- d) Pumphouse & Lift Station housekeeping
- e) Continue to monitor pressure and flow rates; everything is good.
- f) Check well house furnace
- g) Lift station generator tested
- h) Service disconnects as per admin request
- i) Water service restored as per resident request
- j) Camera and sewer auger residential sanitary line as per resident request
- k) Thaw frozen sanitary service at manhole in subdivision west of trailer park
- l) Refer Bulk Water inquiry into water testing for sprayers to ACE Operations.
- m) Month end reporting
- n) Gel Standard tests of hand held Cl2 analyzers
- o) Gas monitors recalibrated by Lakeland Fire & Safety
- p) Check and grease pumps

Other

- a) Service and repair snow removal equipment
- b) Sweep and remove snow and ice from Town sidewalks
- c) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

