

## Roads / Sidewalks

- a) Grade, load and haul snow off all Town roads
- b) Apply beet juice and sand to all intersections and roads as required
- c) Grade ice from gutter for proper drainage during warm weather
- d) Remove snow from back alleys as required
- e) Load and haul snow from back alleys and drainage ditches
- f) Sweep all town sidewalks, fire hall and parking lot at the hall

## Water/Wastewater

- a) The town experienced no power disruption since last report - all systems good
- b) Gel standard tests and cl2 analyzer calibrations done
- c) Manual meter reads as per admin
- d) Continue to monitor pressure and flow rates
- e) Annual reservoir pumphouse housekeeping
- f) Sanitary Lift station generator test
- g) Restored water service to rental property as per request
- h) Manhole checks around town
- i) H2S gas monitors recertified
- j) Frozen water meter replaced as per request
- k) Salt and clear truck fill pad
- l) Feb 10 - thaw frozen sanitary line at 57 street manhole and check adjacent line
- m) Begin training back up operator on water/wastewater routine duties
- n) Feb 18 - frozen sanitary service call out on 57 street- 2 Pw responded and cleared line 90+ feet to under trailer - unable to go further
- o) Feb 21- PW returned to 57 street manhole and were able to clear line at 100 feet - ran steamer into adjacent line while there as well
- p) Sewer camera residence sanitary line as per request and found blockage at 65 feet - cleared by plumber
- q) NOTE: Feb. 14th Bacti sample was not delivered on time and was not processed, additional sample taken in its place on 21st

## Other

- a) Repair and install new lids on 6 garbage containers
- b) Service and repair all snow removal equipment
- c) Replace sideboard on tandem
- d) Replace broom on the New Holland sidewalk sweeper
- e) Complete all service requests

**Note:** Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

