

Roads / Sidewalks

- a) Grade all Town roads
- b) Start hauling windrows of snow
- c) Start grading back alleys
- d) Apply beet juice at major intersections

Water/Wastewater

- a) The town experienced no power disruptions since last report - all systems good
- b) Display panel replaced on ACE control cabinet
- c) Pumphouse and Lift station housekeeping
- d) Continue to monitor pressure and flow rates
- e) Sewer auger residential sanitary line as per request
- f) Flush 51st Ave sewer main and check manholes
- g) Bulk water disruption on Nov. 13th due to fire departments pump testing all county fire trucks on truck fill pad

Other

- a) Put up snow fence in back alley north of 50th Ave, both sides of 51 St at 46 Ave and in Huey park
- b) Push in pipes at Geleta Park entrance and between Rec Centre and Hall for barricades to prevent vehicle entrance
- c) Service dump trucks, loader and grader
- d) Catch stray dog and return to owner
- e) Complete service requests

Note: Public works continues to use Covid 19 Best Practices and standard procedures when dealing with the public and during property entry during the performance of water/wastewater duties