

# Public Works Foreman Report

February 12, 2018

---

## 1. Roads / Sidewalks

- a) Grade all town roads
- b) Grade all town back alleys
- c) Haul windrows of snow off roads
- d) Sand roads and intersections as required
- e) Grade rec centre and arena parking areas

## 2. Water/Wastewater

- a) Programming on new UFD at reservoir adjusted & set point lowered
- b) Located 46st storm sewer by highway 45 as per request
- c) Water break on 47 ave excavated, repaired & tested
- d) Power outage- Reservoir and Lift station ran approximately 2 hours on back up systems
- e) Water break at Two Hills Foods mall- meter froze, meter replaced
- f) Water break at curling rink fire suppression line froze repaired
- g) Completed annual reporting for CAO & operator to review

## 3. Other

- a) Remove snow from town sidewalks
- b) Proudline completed repairs on rec centre fire suppression system and will return once ice is removed to repair ice surface piping and sprinkler heads
- c) Gateway has repaired ice plant piping and filled system with new brine. Pumps have been rebuilt and put back into service
- d) Gateway has repaired and serviced heating system in the rec centre and replaced the hot water pump
- e) Service and repair all snow removal equipment
- f) Complete all service requests