



1. Roads / Sidewalks

- a) Grade streets and clear intersections
- b) During the extreme cold spell, we cleared basic areas only (hospital, school, firehall, RCMP Station). It was too cold to operate the equipment for full days without mechanical problems
- c) Sand & salt some intersections as needed, and for concerned citizens
- d) Clean sidewalks
- e) Clean up at the cemetery funeral
- f) Clean the swimming pool parking lot

2. Water/Wastewater

- a) Investigated 2 complaints of "No Water"- both were due to frozen water lines within the structure- (open basement window next to the water line, and the other one had an outside vent open in the mechanical room)
- b) Annual Alberta Environment Water Distribution Inspection- Approved with no deficiencies
- c) Monitored pump houses during the cold snap
- d) Restore water service as per resident requests
- e) Meet with Randy- Re: Annual Reports Update
- f) Water break at 47 St & 53 Ave Intersection (4 inch line)- isolated, excavated, repaired, and tested in 1 day
- g) 7 day letter submitted to Alberta Environment.

3. Other

- a) Replace starter in the vac truck
- b) Replaced tires on the F-250
- c) Power line accident on 57 Ave near the county shop- repaired by Atco; minus 30-40 windchill
- d) Clean the lagoon (slurry from hydro-vac power poles)
- e) Assist Bumper to Bumper with frozen water line in building
- f) Attended to requests to the best of our ability
- g) Assist Myrnam their water break (equipment & manpower)
- h) Assist the County with sewer problem in Hairy Hill (Vac truck)
- i) Cleaned & repaired the storage tanks
- j) Received 6000L of beet juice for the roads
- k) Purchase new winter gear for Public Works Employees (Thank You)

