

Roads / Sidewalks

- a) Fill, pack and level water line break excavations
- b) Remove snow windrows from FasGas, 48 Ave & 47 St
- c) Fill potholes on 48 St & 51 Ave

Water/Wastewater

- a) The town experienced no power disruption since last report - all systems good
- b) Gel standard tests and cl2 analyzer calibrations done
- c) Manual meter reads as per admin
- d) Continue to monitor pressure and flow rates
- e) Sunday March 5 - call out for frozen sanitary line on 57 Street - thawed 2 lines and
- f) restored flows
- g) ACE control valve replaced in reservoir pumphouse - new valve failed to shutdown on fill cycle and Ace fill needed to be closed manually. Techs returned and adjusted programming and reset solenoids. Valve is working correctly now
- h) Water service disconnect as per request
- i) Manhole checks around town

Other

- a) Steam ice from culverts and catch basins where required
- b) Remove snow from drainage ditches where required
- c) Remove ice from inside arena
- d) Service and repair all equipment
- e) Replace lids and weld new brackets on garbage containers
- f) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

