



1. Roads / Sidewalks

- a) Both shifts in to repair water break at 5209 50 st, water line appears to have been leaking for sometime due to washers on pipe Installed 12" x 6" clamp
- b) Haul out windrows from streets and scrape down some icy patches
- c) Sanded both schools parking lots and bus lanes as per request
- d) Apply beet juice and sand on some icy intersections and hill on 46th st

2. Water/Wastewater

- a) The town experienced two power failures since last report All systems good
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) Rebooted pumphouse security
- d) Generator test at Sanitary Lift station
- e) Continue south side pressure checks
- f) Manhole flows checked on 46 ave as per instruction
- g) Gel standard tests and pumphouse CL2 analyzer recalibration
- h) Monitoring distribution flow rates
- i) PRV emptied
- j) Meter reads and month end reporting
- k) AB ENV wastewater annual reporting (completed and submitted)
- l) Cleaned and salted truck fill pad
- m) Manhole checks done at Hlewkas, 46 str, 49 ave, 50 street, 47 ave 51st ave
- n) Water tower and Geleta park pumphouse furnaces checked
- o) Replaced lockset at water tower as per request
- p) Residential sewer auger and inspection as per request
- q) Checked lagoon
- r) Jan. 25 water break by RCMP detachment – water disruption notices given and break isolated
- s) AB ENV notified, 1st calls made and repair completed Jan 26.
- t) Flushing, testing done as per AB ENV and Bacti samples delivered to Prov lab
- u) Evidence of long-term slow leak into ground at water break site- continue to monitor distribution flowrates – slow leak may have attributed to water losses
- v) Confined space entry into PRV vault to clean and inspect pressure gauges, fittings etc.
- w) Clean sanitary lift station wet cell

3. Other

- a) Take vacuum truck to lift station and agitate wet cell with pressure washer. Pumping 100%
- b) Clean sewer line with auger at 5001 46 st root trouble on homeowner's side
- c) Clean and maintain all town sidewalks
- d) Complete all service requests to the best of our ability

