



1. Roads / Sidewalks

- a) Grade streets and Clear Intersections
- b) Sand Streets, sand from County
- c) Clean sidewalks around Town Facilities
- d) Haul out snow piles around arena, fire hall etc.

2. Water/Wastewater

- a) Response to EMCON regarding saline contamination in sanitary system approved and sent
- b) OHS Inspection – added confined space code of practice to sanitary lift operations manual as per instruction
- c) Attended water operator Marvin Lesnick's Funeral
- d) Calibrate CL2 analyzers and gel standard tests at reservoir pump house
- e) Check all sanitary man holes and added degreaser prior to holidays
- f) Vac PRV
- g) Flushed sanitary line west of hospital and dead-end line on 52 Ave
- h) Monitored water and waste water systems over holidays
- i) Reservoir housekeeping in preparation for January 9th Alberta Environment Inspection
- j) Update reservoir S.O.G documents to reflect change of C.A.O & Water Operations
- k) Month end reporting & Meter reads completed

3. Other

- a) Repair ford tractor hydraulic leaks
- b) Get tanks ready for beet juice storage upon arrival January 6-10th
- c) Check heat & furnaces in all well houses and water tower
- d) Clear snow at cemetery for funeral service
- e) Complete all service requests