



1. Roads / Sidewalks

- a) Grade industrial road
- b) Grade and gravel back alleys as required
- c) Continue to fill, pack and level water line repair excavations
- d) Fill major potholes

2. Water/Wastewater

- a) The town experienced 1 power failures since last report - All systems good
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) Annual Bacti sample taken at Hospital
- d) Seasonal Bacti sample taken at Golf course clubhouse – pre opening protocol
- e) Steamed frozen sanitary line to and from Centennial Hall
- f) Vac PRV
- g) Residential meter check
- h) Monitoring distribution flow rates
- i) Contacted concerned citizen re: town water testing and water source
- j) Checked Manholes north side of town: 51st (Hwy 36), 57th Ave & 46th street
- k) Checked high flow manhole at 55th Ave (infiltration) -no infiltration yet (lots of frost)
- l) Confined space entry to sanitary manhole on 46th Ave to check infiltration
- m) Poor internet and email access at pumphouse
- n) Checked storm drain outfalls and catch basins
- o) Manual fill customers at Truck fill due to uploading issues
- p) Water and sewer monitoring and logging Easter Monday as per Code of practice 3-day requirement
- q) Power failure in Vegreville affecting ACE – monitored reservoir fill cycle April 6 evening
- r) Work on lead sampling plan with Vegreville operators for May sampling
- s) Lift station generator test
- t) Replace faulty water meters as per request

3. Other

- a) Repair manhole cover at FasGas
- b) Remove trees at east end park infested with black knot
- c) Repair and service John Deere track hoe
- d) Repair and service street sweeper
- e) Service mowing equipment
- f) Wash and service sanding truck

