

1. Roads / Sidewalks

- a) Grade all town roads and back alleys
- b) Sand roads and intersections as required
- c) Load and haul snow windrows

2. Water/Wastewater

- a) Continue to monitor ground infiltration on 46 Ave.
- b) Check lagoon flows between calls.
- c) Flush main 54 Ave south on 50 St.
- d) Sewer camera & auger residence as per request
- e) Shut down office pumphouse furnace - meter removed, pump removed.
- f) Check water tower & Geleta Park pumphouse furnaces.
- g) Jetted (county truck) sewer mains 53 Ave North on 48 & 50 St.
- h) Main break on 50 St. – discovered immediately through reservoir monitoring, located and isolated. First calls notified and all notifications given. Approximately 59 m³ lost, repaired, flushed and tested.

3. Other

- a) Disconnect power and gas from well #1
- b) Disconnect gas from well #4 power still on
- c) Remove fire siren from stand and remove the stand
- d) Service and repair all snow removal equipment
- e) Complete all service request
- f) Sweep all town sidewalks, fire hall pad and parking area
- g) Repair down spout and drain grate at the dental clinic