

Roads / Sidewalks

- a) Grade roads and haul windrows as required
- b) Swept sidewalks
- c) Cleared snow from hall parking lot
- d) Grade and cleaned snow from back alleys as required
- e) Sand and salt roads and intersections as per conditions
- f) Sand and salt from Emcon as per agreement
- g) Assembled Beet juice application unit and began laying down beet juice on roads and intersections when needed

Water/Wastewater

- a) The town experienced 0 power disruption since last report -- all systems good
- b) Gel standard tests and cl2 analyzer calibrations done
- c) Restore residential water service as per request
- d) Continue to monitor pressure and flow rates
- e) Shut off commercial water service as per request
- f) Sewer camera residential sanitary line as per request - unable to access due to no clean out access
- g) Excavate and replace leaking cc valve on 50th Ave
- h) Manhole check on 57Street
- i) Generator test at lift station
- j) Diaphragm and seals replaced in Reservoir fill control valve - cavitation damage discovered on basket - will need rebuild kit eventually
- k) Manually fill jugs for barrel fill customers when barrel fill frozen
- l) Continue working on AB ENV annual reporting
- m) Ace communication failure prevented reservoir filling for 3 days, reservoir filled at emergency set point and communication was restored. All systems good
- n) THM's and Lead samples taken
- o) Low room temp. alarm from sanitary lift station responded to by On Call worker during extreme cold
- p) Drip list reminder notices delivered to all affected properties
- q) Fire extinguishers and emergency lights recertified at Sanitary lift station and Reservoir pumphouse

Other

- a) Took single axle dump truck to International in Edmonton for service and picked up
- b) Put up Christmas lights on light poles
- c) Fire extinguishers in town equipment and shops recertified
- d) Push up snow at snow dump storage location to ensure adequate space

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

