



Roads / Sidewalks

- a) Grade snow and ice off all roads
- b) Grade snow and ice off all back alleys
- c) Load and haul snow windrows
- d) Haul snow from problem back alleys
- e) Grade snow off for dumping south of 50 Ave at 53 St
- f) Apply beet juice at intersections and on roads where required
- g) Sweep sidewalks as required
- h) Grade snow off hall parking lot

Water/Wastewater

- a) The Town experienced no power disruptions since last report - all systems good
- b) Natural gas regulator replaced by Apex at reservoir pumphouse
- c) Engine driven stand pump tested after gas disruption
- d) Pumphouse and lift station housekeeping
- e) Continue to monitor pressure and flow rates
- f) Check well house & reservoir furnaces
- g) Lift station generator test
- h) Service disconnects & reconnects as per admin request

Other

- a) Service and repair all snow removal equipment
- b) Complete service requests

Note: Public works continues to use Covid 19 Best Practices and standard procedures when dealing with the public and during property entry during the performance of water/ wastewater duties

