

## Roads / Sidewalks

- a. Grade industrial road 51 St, 57 Ave
- b. Grade 47 Ave from 54 to 56 St
- c. Grade back alleys
- d. Repair back alleys with gravel north of the mall

## Water/Wastewater

- a) The town experienced 2 power disruptions since last report-all systems good
- b) Calibrate pumphouse CL2 analyzer
- c) Continue to monitor CL2 levels throughout distribution system- levels still lower than normal but within acceptable range. Approximately 1500 M3 of water was used while flushing through town facilities to raise CL2 levels within the distribution system
- d) Annual lagoon release ended morning of October 16<sup>th</sup>
- e) Lagoon release valve excavated and repaired by Public Works
- f) Several residential meters replaced as per request
- g) Sanitary lift station wet cell cleaned
- h) Service disconnects as per admin request

Note: Lower than normal CL2 levels have been an issue throughout the province since late July due to issues at source (EPCOR), water charges for system flushing will be reimbursed by ACE

## Other

- a. Complete backfilling on both sides of the new gutter on 52 St between 45 and 47 Ave
- b. Moved address sign post at 44 St and 48 Ave
- c. Mow back alley north of 50 Ave
- d. Service, repair and winterize all mower equipment for storage
- e. Remove the water tank for watering flowers
- f. Received 10 cubes of beet juice for ice control
- g. Change oil in trucks, dump truck and snow removal equipment
- h. Excavate 12" valve at the lagoon and repair it, back fill and pack
- i. Monitor repairs and servicing of the ice plant
- j. Complete all service requests

