

Roads / Sidewalks

- a) Grade all gravel roads
- b) Grade back alleys as required
- c) Start road sweeping
- d) Begin filling pot holes
- e) Repair water line break excavation with gravel and pack it
- f) Gravel and grade the parking lot at the west side of the arena
- g) Remove snow and ice from drainage ditches and culverts

Water/Wastewater

- a) The Town experienced no power disruptions since last report - all systems good
- b) No Bacti sample taken on March 8th due to extreme road conditions (no AHS courier) additional samples taken following week to ensure no contravention
- c) Pumphouse and lift station housekeeping
- d) Continue to monitor pressure and flow rates
- e) Review and update sanitary lift station high risk rescue plan - posted GPS location on site for 911
- f) Ordered signs for highway 36 (to help first responders locate lift station in event of an emergency)
- g) Lift station generator test
- h) Service disconnects/reconnects as per admin request
- i) Grease pump drives and clean lift station cell
- j) Attempt to thaw frozen service from beneath mobile home - temporary service installed
- k) Attended AWWOA Conference
- l) Received and warehoused new water meters registers and transmitters at the reservoir
- m) Gel standard tests of hand held cl2 analyzers
- n) Notified by PanDakota Dive Services that we had won an underwater facility inspection door prize at the AWWOA conference (approximate savings of \$2000) they conducted an ROV (remote operated vehicle) underwater reservoir inspection of all 3 reservoir storage cells and pumps - very little silt, no concerns. Next inspection won't be required until spring 2027
- o) PRV vault vac'd out
- p) Sanitary line from public works thawed out and sump vac'd





Other

- a) Wash service and get CVIP done on dump trucks
- b) Wash and service skid steer, loader, mini hoe and service trucks
- c) New tires installed on tandem dump truck
- d) Service sweeper for the loader
- e) Service road sweeper (new side brooms)
- f) Replace lids and repair brackets on 15 garbage bins
- g) Install new batteries in scissor lift
- h) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

