

1. Roads / Sidewalks

- a) Grade ice from gutters where required
- b) Grade and haul snow from ditches for proper drainage
- c) Remove snow and ice from all catch basins and culverts
- d) Grade 54 St and Golf Course parking lot
- e) Begin pothole filling & repairs

2. Water/Wastewater

- a) The town experienced no power failures since last report - All systems good
- b) Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) Lift station call out- room temp- all clear
- d) Assisted contractors with lateral sanitary line replacement at Hillside Lodge
- e) Water break at Hillside lodge – isolated and reported to AB ENV, monitored repair by onsite contractors, flushed and tested as per code of practice.
- f) AWWOA water and wastewater sessions March 9 -12th
- g) Began updating safety training
- h) Monitoring distribution flow rates
- i) Thaw storm drain south of Mennonite school on 49th street
- j) Thaw culvert south of TH School 48th street
- k) Checked Manholes west side of town:
 - (1) 52nd,53rd, 54th streets
 - (2) 50th Ave, 47th Ave
 - (3) 46th street
- l) High flow manhole at 46th Ave (infiltration)
- m) Confrontational person property entry for meter check/replacement with assistance of RCMP
- n) Began developing a Confrontational/ difficult person property entry Standard operating Procedure
- o) Checked storm drain outfalls and catch basins

3. Other

- a) Close all garbage can lids
- b) Repair and replace garbage can lids
- c) Steam ice from frozen catch basins and culverts
- d) Service and repair all equipment
- e) Complete all service requests