

Roads / Sidewalks

- a) Applied de-icer to all Town sidewalks as needed
- b) Sand and salt intersections where needed
- c) Picked up sand and salt mixture from EMCON
- d) Grade areas as needed-Isaac in training
- e) Apply beet juice to roads
- f) Sand and salt applied to both school parking lots

Water/Wastewater

- a) The town experienced 0 power disruptions since last report-all systems good
- b) Calibrate pumphouse cl2 analyzer
- c) Continue to monitor Cl2 levels throughout distribution system - levels are back to normal
- d) Continue winter treatment cycle with sanitary system
- e) Reservoir pumphouse housekeeping
- f) Remove snow and add Ice melt to truck fill pad as required
- g) Service reconnects as per admin request
- h) Meter replacement as per admin request (meter not working since 2021)
- i) Meter installs as per admin request
- j) Emptied PRV

Other

- a) Plumber replaced furnace in grader shop
- b) Service and repair snow removal equipment
- c) Replace battery in the loader
- d) Repair hoses on skidsteer sweeper
- e) Complete all service requests

