



## Roads / Sidewalks

- a) Grade snow off all Town roads
- b) Grade back alleys
- c) Load and haul all windrows
- d) Apply beet juice, salt and sand mix on intersections where required
- e) Load and haul snow off of both sides of highway 36
- f) Clean snow off all town sidewalks and fire department pad

## Water/Wastewater

- a) The Town experienced no power disruptions since last report – all systems good
- b) Low room temperature at lift station was -51 with wind, added space heater
- c) Pumphouse and lift station housekeeping
- d) Continue to monitor pressure and flow rates
- e) Check well house furnace
- f) Lift station generator test
- g) Continue to work on annual reporting
- h) Internet disruption at reservoir ( 6 Days )
- i) Additional Bacti samples taken in preparation for Lab shutdown over holidays

## Other

- a) Complete all service requests

Note: Public works continues to use Covid 19 Best Practices and standard procedures when dealing with the public and during property entry during the performance of water/wastewater duties

