

Roads / Sidewalks

- a) Grade 52 St, 53 Ave, 52 Ave
- b) Repack and fill water line break excavations
- c) Grade hall parking lot and entrance road
- d) Fill potholes on 46 St, 47 Ave, 50 Ave

Water/Wastewater

- a) The Town experienced 0 power disruptions since last report --- all systems good
- b) Calibrate pumphouse cl2 analyzer
- c) Gel Standard tests completed
- d) PRV vault vac'd
- e) 50Hp pumps exercised at Reservoir pumphouse
- f) Well house furnace checked
- g) Visual inspection of lagoons
- h) Delivered water service disconnect notice as per admin
- i) Met with ACE rep regarding potential short term disruption of Bulk water sales at Reservoir truckfill during tie in to new water line to Duvernay
- j) Communications failure at Reservoir - resolved by ACE - fill cycle disrupted for 24hours
- k) 50Th avenue water break- located. Isolated, repaired, flushed and tested as per code of practice. Circular break repaired under positive pressure.
- l) Note: Valves on east side of 46 street need repair. PW unable to completely isolate line
- m) at nearby valves
- n) 51 st avenue water break- located, isolated, repaired, flushed and tested as per code of practice. Circular Break repaired under positive pressure.
- o) Ledcor moved telus junction box at reservoir over ACE fill line - ACE and Telus notified and Ledcor will be moving junction box to nonconflicting location close by
- p) Continue to monitor flow rates

Other

- a) Supply part and pick up single axel truck from Diamond International in Edmonton
- b) Remove all concrete from Chronicle location and lot next to it, back fill and pack it
- c) Send dump trucks and Vac truck for CVIP
- d) Remove all snow fence and posts from snow drifting locations
- e) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

