

Roads / Sidewalks

- a) Dig up old culvert and replace
- b) Back fill and level culvert excavation
- c) Prepare road for reclaimer
- d) Haul reclaimed asphalt to stockpile
- e) Lower manholes as required
- f) Sweep and clean gutters as required
- g) Add temporary driveway approaches

Water/Wastewater

- a) The town experienced no power disruptions since last report - PEAK is still waiting
- b) for Back up engine oil pressure sensor and will install as soon as available
- c) Gel standard tests and cl2 analyzer calibrations done
- d) Restore residential water service as per request
- e) Continue to monitor pressure and flow rates
- f) Non payment water disconnects as per office
- g) RV dump closed for season
- h) 1 residential sewer camera job as per requests
- i) Manhole checks around town
- j) Generator test at lift station
- k) Gate valves outside of Reservoir pumphouse located by ACE for Duvernay line tie in
- l) Geleta park water lines shut off and winterized
- m) Vac PRV vault behind public works
- n) Flush and vac several sanitary mains around town with Urlacher
- o) Large blockage east of School removed
- p) Large blockage towards north end of 50street removed
- q) Annual lagoon release notifications sent
- r) Lagoon release valve tested and checked
- s) 47 ave storm water culvert job completed
- t) BOD and CBOD samples taken and sent to lab in prep for annual release

Other

- a) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

